Phigenics Validation Test®

PHIGENICS ANALYTICAL SERVICES LABORATORY
www.phigenics.com
Phone: 844-850-4087
CDC ELITE Certified
Illinois Laboratory: 3S701 West Ave STE 100, Warrenville, IL 60555
Arkansas Laboratory: 4375 N Vantage Dr STE A104, Fayetteville, AR 72703

Customer Name: Illinois Department of Corrections Pontiac
Customer Code: ILLI0011
PO: Verbal Jared Brunk
Work Order: WO-2022-002518
Contact Name: Anthony Harrell
Contact Email: aharrell@phigenics.com

Phigenics Validation Test Report Summary

PASL Number	Date Collected	Date Analyzed	Collector	Sample Location Description	Conductivity µS/cm	pH	Total Dissolved Solids mg/L
1018578	2022/06/07	2022/06/20	A. Harrell	Pontiac Bldg East Cell House Fl 1 Rm Cell 103 Inmate Cell Sink C	724	7.97	353
			*Inmate had mattres material over sink spout as a filter. Sampled with mattress material dripping into sample bottle.				

Disclaimer: Results from Phigenics analytical test methods do not provide enough evidence to ensure that hazards from pathogenic microorganisms or chemical hazards have been eliminated or controlled, nor that risk of harm from such hazards have been reduced. Results from Phigenics analytical tests should only be interpreted within the context of properly designed and implemented water management programs. No guarantee regarding results is expressed or implied. Phigenics analytical test methods and the results produced are provided on an "as is" basis. Results relate only to the sample(s) received by the Phigenics laboratory in connection with this Validation Test. The user assumes total responsibility and risk for the use of the Phigenics analytical test(s) and the results from the test(s). PHIGENICS IS NEITHER RESPONSIBLE NOR LIABLE FOR ANY DAMAGES ARISING OUT OF YOUR USE OF PHIGENICS ANALYTICAL TEST METHODS AND RESULTS. This report shall not be reproduced except in full and with the written approval of Phigenics LLC.

phigenics Analytical Services Laboratory

Copyright © 2006 - 2022 Phigenics, LLC All Rights Reserved