

## DISTRIBUTION TESTING

Date: 11-14-18

Technician: NR

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admiral	3.33	0.01	0.055
15	Luigi	3.29	0.01	0.066
16	Court	<del>M<sup>2</sup></del> 3.43	0.02	0.071
17	liq p-1	3.35	0.05	0.085
18	Fen	3.27	0.02	0.073
19	KEH	3.38	0.02	0.563
29	Maxi	3.43	0.02	0.101
23	Sams	3.41	0.02	<del>0.095</del> 0.08

Comments:

---



---



---



---



---



---

# DISTRIBUTION TESTING

Date: 11-13-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.43	0.02	0.099
8	NFA	3.55	0.00	0.053
9	Clio	3.36	0.00	0.052
10	Autoz	3.47	0.01	0.058
12	Hoff	3.29	0.02	0.109
13	6 Mas	3.33	0.02	0.069
26	Bs	3.38	0.02	0.085
27	Hassel	3.45	0.01	0.052

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 11-12-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	UN MARK	3.37	0.02	0.096
2	10 Fu	3.45	0.01	0.074
3	Pal lit	3.50	0.01	0.122
4	COLUN	3.49	0.03	0.113
5	L Res	3.46	0.01	0.119
6	Yeo	3.40	0.03	0.192
28	FIA	3.52	0.01	0.102
21	DONS	3.38	0.01	0.060

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 11-9-18

Technician: BA/AR

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W. Res	3.32	0.02	0.183
15	Luigi's	<del>3.85</del> 3.66 3.83	<del>0.01</del> 0.05 0.09	0.592 <del>0.792</del>
16	RA Court	3.46	0.01	0.052
17	Liq Pul	3.42	0.00	0.085
18	KA Fenton	3.31	0.01	0.074
19	14 E H	3.37	0.01	0.082
30	ADESA	3.49	0.02	0.103
22	<del>Hamilton Hessel</del>			
25	Fire 5	3.44	0.00	0.206
	Hamilton	3.37		

Comments:

---



---



---



---



---



---

# DISTRIBUTION TESTING

Date: 11-8-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	Fire 3	3.36	0.02	0.106
1	UN MARK	3.39	0.02	0.150
2	10 Fu	3.45	0.01	0.068
3	Pal lil	3.45	0.02	0.105
4	COLO.	3.43	0.01	0.116
5	C RES	3.46	0.03	0.108
27	MAX	3.47	0.03	0.067
29	MAX	3.41	0.02	0.068
23	SUM	3.35	0.00	0.069
24	Gen H	3.47	0.02	0.066

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: ~~11-16~~ 11-6-18

Technician: BP/AR

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.65	0.06	0.443
9	NFA	3.57	0.02	0.048
9	Clio	3.57	0.03	0.057
10	Acutor	3.48	0.03	0.047
12	Huff	3.22	0.02	0.091
13	Gmas	3.26	0.04	0.060
14	Admi	3.34	0.03	0.051
19	NELH	3.36	0.03	0.060
26	Bs	3.30	0.03	0.068
<del>27</del>	<del>Hess</del>			
	Hamilton	3.22		

Comments:

---

---

---

---

---

---

---

---

### DISTRIBUTION TESTING

Date: 11-5-18

Technician: BP/AP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	UN MILL	3.28	0.04	0.178
4	COIV.	3.36	0.02	0.117
5	CRES	3.44	0.02	0.115
6	YCO	3.30	0.04	0.142
16	COVIT	3.35	0.01	0.056
17	119 P11	3.36	0.04	0.081
28	PIA	3.37	0.05	0.219
21	DANS	3.31	0.02	0.066

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 11-2-19

Technician: BP/AR

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W RES	3.30	0.04	0.225
16	COVY	3.48	0.02	0.057
17	117 P21	3.42	0.01	0.095
18	FCU	3.29	0.02	0.054
19	IV E H	3.36	0.01	0.074
30	A DESA	3.43	0.01	0.073
25	File 5	<u>3.49</u> 4.77	0.02	<del>0.227</del> 1.36

Comments:

---



---



---



---



---



---



---



# DISTRIBUTION TESTING

Date: 11-1-18

Technician: BP / AR

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	UAM Mark	3.37	0.02	0.154
2	10 Fu	3.36	0.01	0.089
3	Pal 107	3.44	0.01	0.105
4	RA Cor.	3.44	0.01	0.112
5	Ced Kes	3.45	0.01	0.132
27	Martinez	3.46	0.01	0.067
24	Gen H	3.26	0.01	0.059
	HAm.	3.34		

Comments:

---

---

---

---

---

---

---

---

### DISTRIBUTION TESTING

Date: 10-31-18

Technician: BP/RA

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admiral	3.31	0.01	0.055
15	Luigi's	3.25	0.02	0.072
16	RA Court	3.39	0.02	0.052
17	1.9 Pal	3.40	0.01	0.074
18	RA Fen	3.20	0.02	0.077
19	NF 11	3.31	0.01	0.089
29	Maxi	3.40	0.02	0.059
23	Sams	3.29	0.01	0.064

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 10-30-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.29	0.03	0.101
8	NFA	3.48	0.00	0.052
9	Clio	3.33	0.01	0.056
10	Autoz	3.41	0.03	0.049
12	Hdfl	3.33	0.02	0.094
13	Gms	3.25	0.01	0.049
26	Bs	3.29	0.01	0.073
22	Vgsfel	3.28	0.01	0.047
	Hamilton	3.22		
			0.02	

- .21  
- .28  
- .29

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 10-29-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	UN MARK	3.26	0.02	0.077
2	10 Fu	3.40	0.02	0.065
3	Pal lig	3.40	0.01	0.094
4	COGVA	3.40	0.02	0.092
5	C RES	3.43	0.01	0.152
6	Yco	3.31	0.02	0.090
28	FIA	3.45	0.02	0.150
21	Don	3.32	0.02	<del>0.04</del> 0.047
	TAP	3.55		

Comments:

---



---



---



---



---



---



---

# DISTRIBUTION TESTING

Date: 10-26-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W Res	3.11	0.04	0.241
16	Court	3.40	0.03	0.057
17	1.9 Pl	3.12	0.01	0.104
18	Fen	3.21	0.01	0.100
19	NEH	3.18	0.02	0.085
30	ADESA	3.27	0.00	0.071
25	Fire 5	3.37	0.01	0.143
	VA. Market	3.18		
	Luigi's	3.31		

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 10-25-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	Fire 3	3.14	0.02	0.051
1	va mark	3.08	0.02	0.076
2	10 fu	3.25	0.03	0.080
3	Pal itig	3.34	0.02	0.175
4	R Coburn	3.34	0.01	0.208
5	C Res	3.42	0.02	0.192
27	una	3.54	0.02	0.083
24	ben h	3.19	0.01	0.053
	Luigi's	3.81		
	Hamilton	3.16		

Comments:

---



---



---



---



---



---



---

## DISTRIBUTION TESTING

Date: 10-24-18

Technician: VBP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admi	3.16	0.02	0.061
15	Lvi-	3.04	0.02	0.064
16	Coat	3.32	0.01	0.066
17	liq Pri	3.34	0.02	0.121
14	Fcu	3.14	0.01	0.069
19	NEH	3.10 <del>2.99</del>	0.02	0.084
29	M 4xi	3.28	0.00	0.077
23	SAMS	3.15	0.01	0.072
	Hassel bring	3.11		
	Grandmas	3.11		
	Foss	3.26		

Comments:

---



---



---



---



---



---



---

## DISTRIBUTION TESTING

Date: 10-23-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	2.31 3.20	0.03	<del>0.310</del> 0.14
8	NFA	3.20	0.02	0.098
9	Clio	3.14	0.02	0.154
10	Autot	3.12 <del>3.02</del>	0.01	0.086
11	Hoff	3.13 <del>2.45</del>	0.03	0.310
13	G Mas	2.68 3.11	0.01	0.066
26	Br	3.20	0.01	0.057
27	Hessel	2.57 3.11	0.01	0.089
	Hamilton	2.73		
	Dons	3.14 <del>2.45</del>		
	Place	3.29		
	TAP	3.57		

Comments:

---



---



---



---



---



---



---



## DISTRIBUTION TESTING

Date: 10-22-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	UN mark	3.18	0.01	0.196
2	10 Fu	2.71 *	0.03	0.532
3	Pal 1.7	4.13 *	0.05	1.32
4	COU	3.65	0.03	1.05
5	C Res	3.45	0.02	0.481
6	yeo	3.83	0.04	1.59
28	FSA	3.62	0.03	1.57
21	Don	3.00 * 3.14	0.02	0.397

Comments:

0.04

---



---



---



---



---



---



---

# DISTRIBUTION TESTING

Date: 10-19-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	Res	3.26	0.03	0.209
16	Kourt	3.36	0.00	0.053
17	liq pit	3.38	0.01	0.086
18	Fen	3.33	0.01	0.085
19	NEH	3.31	0.01	0.078
30	ADESA	3.34	0.02	0.083
25	Fire 5	3.25	0.03	0.084

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 10-18-19

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	Fire 3	3.18	0.00	0.066
1	UN Mark	3.26	0.00	0.125
2	10 Fu	5.21 <del>3.41</del>	0.00	0.077
3	Pal 114	3.46 <del>3.39</del>	0.01	0.144
4	Corun	3.39 <del>3.42</del>	0.00	0.137
5	ced Res	3.42 <del>3.34</del>	0.01	0.138
27	Mara	3.34 <del>3.18</del>	0.00	0.065
24	ben 11	3.18	0.00	0.045

Comments:

---



---



---



---



---



---



---

## DISTRIBUTION TESTING

Date: 10-17-19

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admi	3.17	0.01	0.094
15	Loi	<del>3.17</del> 3.13	0.01	0.065
16	Covert	3.13	0.00	0.073
17	liq pal	3.37	0.00	0.132
18	Fen	<del>3.16</del> 3.15	0.00	0.052
19	NEH	3.13	0.00	0.080
29	MAXI	3.25	0.00	0.083
23	Sams	<del>3.23</del> <del>3.13</del> 3.23	0.00	0.116

Comments:

---



---



---



---



---



---



---

# DISTRIBUTION TESTING

Date: 10-16-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.49	0.03	0.111
8	WFA	3.48	0.00	0.081
9	Cliv	3.65	0.00	0.309
10	Autoz	3.38	0.00	0.090
12	Hoff	3.38	0.01	0.126
13	6 Mas	3.33	0.02	0.058
26	BS	3.36	0.01	0.081
28	Hassel	3.37	0.00	0.057

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 10-15-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	un mark	3.39	0.01	0.095
2	10 Fu	3.29	0.01	0.056
3	Put lig	3.49	0.01	0.123
4	Lopanna	3.40	0.00	0.066
5	ced Res	3.46	0.00	0.097
6	yeol	3.28	0.01	0.072
28	FIA	3.49	0.08	0.246
21	Don	3.31	0.00	0.048

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 10-12-19

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W. Res	3.37	0.04	0.219
16	Court	3.39	0.01	0.061
17	119 pl	3.34	0.01	0.075
18	Fca	3.31	0.02	0.049
19	MEH	3.31	0.01	0.057
30	ADESA	3.38	0.01	0.103
25	Fire 5	3.33	0.02	0.083
	Hamilton	3.24		

Comments:

---

---

---

---

---

---

---

---

### DISTRIBUTION TESTING

Date: 10-11-19

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	Fire 3	3.37	0.02	0.050
1	Un Mark	3.34	0.02	0.055
2	Ten Fu	3.22	0.01	0.055
3	Pal 119	3.43	0.01	0.089
4	Corun	3.42	0.01	0.102
5	Ced Res	3.44	0.01	0.083
27	Mara	3.41	0.00	0.060
24	Gen 14	3.39	0.01	0.038

Comments:

---

---

---

---

---

---

---

---



# DISTRIBUTION TESTING

Date: 10-10-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admiral	3.44	0.01	<del>0.053</del> 0.049
15	Lvi	3.37	0.03	0.094
16	Cover	3.53	0.02	0.047
17	liq pit	3.45	0.01	0.064
18	Fca	3.34	0.01	0.051
19	14E4	3.41	0.01	0.079
29	Max	3.53	0.00	0.057
23	Sams	3.41	0.01	0.066
	Hamilton	3.21		

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 10-9-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.39	0.04	0.131
8	IFA	3.55	0.01	0.044
9	Clio	3.42	0.01	0.059
10	Autoz	3.42	0.01	0.049
12	Hoff	3.25	0.02	0.090
13	Gms	3.34	0.01	0.055
26	Bs	3.35	0.01	0.055
22	Hassel	3.41	0.01	0.052
	3602 Brownell	3.40	0.01	0.044

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 10-8-18

Technician: DP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	VA Market	3.38	0.02	0.064
2	10 Fu	3.16 <u>3.21</u>	0.00	0.067
3	Pal 19	3.46	0.01	0.092
4	Column	3.45	0.01	0.087
5	Ced Res	3.50	0.01	0.093
6	yeotis	3.44	0.03	0.170
28	FIA	3.46	0.02	0.093
21	DONS	3.40	0.00	0.062
	HAMILTON	3.17 3.22		

Comments:

---



---



---



---



---



---

# DISTRIBUTION TESTING

Date: 10-5-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W Res	3.36	0.04	0.173
16	Quint	3.46	0.01	0.056
17	Cig Pal	3.60	0.02	0.074
18	Fenton	3.30	0.02	0.049
19	NEH	3.45	0.02	0.105
30	ADISA	3.58	0.02	0.066
25	Five 5	3.51	0.03	0.116

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 10-4-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	FIVE 3	3.28	0.02	0.061
1	VA MARK	3.37	0.04	0.108
2	10 FU	3.21	0.02	0.070
3	Pal 1.9	3.33	0.11	0.159
4	RA CORU	3.29	0.03	0.096
5	CE d RES	3.48	0.01	0.086
27	MARA	3.59	0.01	0.084
24	Gen 14	3.32	0.01	0.056

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 10-3-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Adm	3.40	0.02	0.052
15	CVI	3.28	0.02	0.056
16	ELMT	3.38	0.02	0.058
17	City pl	3.42	0.02	0.049
18	Feu	3.33	0.02	0.072
19	NEH	3.33	0.02	0.074
21	Maxi	3.41	0.01	0.055
23	Sams	3.36	0.02	0.066

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 10-2-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.37	0.02	0.092
8	NFA	3.44	0.01	0.061
9	Cliv	3.46	0.01	0.067
10	Autoz	3.44	0.02	0.067
12	Hoff	3.29	0.03	0.157
13	Grand	3.27	0.01	0.063
06	Bs	3.26	0.02	0.060
02	Hassel	3.32	0.01	0.054

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 10-1-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	UN Mart	3.36	0.00	0.080
<del>2</del>	<del>10 Fu</del>			
3	Pal liq	3.42	0.02	0.077
4	RA Cow	3.42	0.00	0.080
5	ced Res	3.48	0.01	0.083
6	Yeo	3.45	0.01	0.129
28	FIA	3.40	0.05	0.166
21	Don	3.30	0.00	0.053

Comments:

---

---

---

---

---

---

---

---



# DISTRIBUTION TESTING

Date: 9-28-14

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W RES	3.38	0.04	0.176
16	RA COW	3.38	0.00	0.056
17	1.9 P-1	3.58	0.00	0.060
18	RA FCU	3.28	0.01	0.042
19	NEH	3.37	0.01	0.088
30	ADESA	3.48	0.01	0.068
<del>25</del>	<del>FIVE 5</del>			

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-27-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	File 3	3.27	0.02	0.058
1	UN MARK	3.32	0.02	0.061
2	10 Fu	3.21	0.01	0.055
3	Pal 119	3.43	0.01	0.074
4	RA CORU	3.42	0.01	0.083
5	ced Res	3.47	0.01	<del>0.080</del> 0.087
27	Mara	3.47	0.01	0.069
24	ben 14	3.42	0.01	0.060

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-26-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admiral	3.40	0.01	0.047
<del>15</del>	<del>Luigi</del>			
16	RA Court	3.43	0.01	0.048
17	119 Pal	3.49	0.01	0.063
18	RA Fen	3.26	0.02	0.074
19	NEH	3.39	0.01	0.053
29	Maxi	3.44	0.01	0.072
23	Sams	3.37	0.01	0.066

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-25-14

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.36	0.02	0.138
8	NFA	3.43	0.00	0.055
9	R1 Clo	3.29	0.01	0.059
10	Autoz	3.41	0.01	0.049
12	Hoff	3.36	0.02	0.209
13	Grand	3.24	0.01	0.062
26	MRB	3.33	0.01	0.078
28	Hassel	3.24	0.01	0.071

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-24-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	UN mark	3.31	0.02	0.058
2	10 Fu	3.25	0.01	0.068
3	Pal liq	3.36	0.02	0.081
4	RA colu	3.37	0.02	0.091
5	Ced Res	3.52	0.02	0.090
6	Yeastis	3.36	0.02	0.082
28	FEA	3.32	0.05	0.143
21	Dons	3.27	0.01	0.049

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 9-21-19

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
3	Pal liq	3.51	0.01	0.100
5	ced Res	3.52	0.01	0.084
11	w. Res	3.43	0.04	0.186
16	RA covr	3.48	0.01	0.096
17	liq Pal	3.58	0.01	0.074
18	RA <sup>fe on</sup> <del>covr</del>	3.36	0.01	0.110
19	NV 14	3.42	0.02	0.088
30	ADESA	3.54	0.01	0.064
25	Five 5	3.58	0.04	0.289

Comments:

---



---



---



---



---



---



---

# DISTRIBUTION TESTING

Date: 9-19-19

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admiral	3.42	0.01	0.049
15	Luigi	3.38	0.02	0.061
16	R1 covr	3.45	0.00	0.052
17	liq pal	3.21	0.00	0.063
18	R1 Fen	3.33	0.01	0.054
19	MEH	3.40	0.02	0.075
21	Maxi	3.48	0.00	0.055
23	SAMS	3.40	0.01	0.075

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-18-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.48	0.03	0.171
8	NFA	3.46	0.01	0.046
9	RA Clio	3.49	0.01	0.058
10	Auroz	3.46	0.01	0.050
12	HFF	3.39	0.01	0.119
13	Grand	3.32	0.01	0.054
26	Bs	3.44	0.02	0.094
22	Hassel	3.36	0.01	0.045

Comments:

---

---

---

---

---

---

---

---



# DISTRIBUTION TESTING

Date: 9-17-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	VA MARK	3.28	0.01	0.048
2	10 FU	3.21	0.00	0.078
<del>3</del>	<del>Pat 119</del>			
4	RACON	3.56	0.03	0.192
5	Led Res	3.50	0.02	0.092
6	Yeris	3.46	0.01	0.070
28	FIA	3.49	0.01	0.099
21	Dons	3.37	0.01	0.076

Comments:

---

---

---

---

---

---

---

---

### DISTRIBUTION TESTING

Date: 9-14-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W RCS	3.44	0.03	0.166
16	RA COUV	3.44	0.02	0.048
17	1.4 PAL	3.55	0.02	0.061
18	RA COOL PEN	3.36	0.01	0.045
19	NEH	3.47	0.02	0.092
30	ADESA	3.55	0.01	0.058
25	Fire 5	3.43	0.02	0.132

Comments:

---

---

---

---

---

---

---

---

### DISTRIBUTION TESTING

Date: 9-13-14

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	Fire 3	3.32	0.03	0.055
1	UN MARK	3.38	0.02	0.063
2	10 Fu	3.25	0.01	0.079
3	Pat liq	3.46	0.02	0.100
4	RA CORU	3.53	0.01	0.125
5	ced RES	3.56	0.00	0.099
27	Mara	3.62	0.01	0.071
24	Gen Health	3.42	0.01	0.054

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 4-12-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admiral	3.44	0.01	0.053
15	Luigi	3.34	0.04	0.087
16	RA Court	3.50	0.00	0.057
17	117 Pl	3.51	0.02	0.089
18	RA Pen	3.35	0.02	0.060
19	NEH	3.62	0.04	0.356
21	Maxi	3.50	0.01	0.065
23	Sans	3.45	0.01	0.076

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-11-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.38	0.02	0.101
8	NFA	3.44	0.02	0.078
9	RA clio	3.47	0.02	0.071
10	Auto 2	3.47	0.02	0.091
12	Hoff	3.28	0.04	0.106
13	Grand	3.28	0.02	0.061
26	MR B	3.23	0.05	0.094
22	Hassel	3.34	0.01	0.067

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-10-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	UN Mark	3.38	0.02	0.079
2	10 Fu	3.21	0.01	0.080
3	Pal 1.9	3.46	0.01	0.088
4	RA covv	3.45	0.01	0.081
5	ced Kes	3.54	0.01	0.106
6	yeon's	3.44	0.02	0.139
28	FIA	3.45	0.03	0.160
21	Dons	3.32	0.01	0.055

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-7-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W. Res	3.47	0.04	0.144
16	RA cov	3.49	0.01	0.065
17	Liq Pl	3.30	0.01	0.086
18	KA Fen	3.40	0.01	0.063
19	NEH	3.39	0.03	0.177
30	ADESA	3.44	0.01	0.075
25	File 5	3.50	—	0.061

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 9-6-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	Fire 3	3.32	0.01	0.049
1	UN MARK	3.40	0.05	0.100
2	10 Fu	3.25	0.01	0.054
3	Pal liq	3.59	0.07	0.270
5	Ced Res	3.56	0.03	0.105
27	Masa	3.55	0.01	0.070
28	FIA	3.51	0.05	0.189
<del>24</del>	<del>Gen Health</del>			
	Hamilton	3.23	0.02	0.098

Comments:

---

---

---

---

---

---

---

---



# DISTRIBUTION TESTING

Date: 9-5-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
4	RA Corunna	3.52	0.04	0.107
14	Admiral	3.50	0.01	0.044
15	Luigis	3.45	0.02	0.107
16	RA Court	3.48	0.01	0.052
17	liquor Palace	3.57	0.01	0.140
18	RA Fenton	3.37	0.03	0.081
19	NEH	3.55	0.02	0.195
29	Maxi	3.50	0.01	0.051
23	SAMS	3.51	—	0.060

Comments:

---

---

---

---

---

---

---

---

### DISTRIBUTION TESTING

Date: 9-4-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	Univ. mark	3.47	0.01	0.109
5	Cedar Kes	3.53	0.01	0.092
7	Foss	3.52	0.02	0.145
8	NFA	3.55	0.00	0.061
9	RA Cliv	3.55	0.00	0.072
10	Autozone	3.55	0.01	0.052
12	Hoffmans	3.25	0.01	0.075
13	Grundmans	3.39	0.02	0.058
26	M.R. B's	3.51	0.01	0.063
21	Dons	3.43	—	0.049
27	Hasselbring	3.39	—	0.055

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 8-31-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W Res	3.47	0.02	0.134
16	R.A. Carr	3.53	0.01	0.072
17	Liq. Pnl.	3.59	0.00	0.091
18	R.A. Fen	3.47	0.01	0.059
19	NEH	3.46	0.00	0.056
30	ADESA	3.53	0.01	0.054
25	File #5	3.49	—	0.072

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 8-30-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	Fire 3	3.32	0.01	0.051
1	Un mark	3.46	0.01	0.088
2	Ten Fu	3.24	0.01	0.101
3	Pal 1.9	3.52	0.02	0.084
4	RA Cdu	3.58	0.01	0.113
5	ced Res	3.58	0.02	0.097
27	Marathon	3.58	0.00	0.053
24	Gen. Health	3.43	—	0.038

Comments:

---

---

---

---

---

---

---

---

## DISTRIBUTION TESTING

Date: 8-29-19

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admi	3.50	0.01	0.052
15	Luigi	3.39	0.02	0.067
16	RA covv	3.49	0.01	0.043
17	Li-q Pal	3.48	0.01	0.072
18	RA Fen	3.40	0.02	0.052
19	IVEH	3.41	0.02	<del>0.090</del> 0.053
29	MAKI		0.09	1.19
23	SAMS	<del>0.09</del>	—	0.057

Comments:

---



---



---



---



---



---



---

# DISTRIBUTION TESTING

Date: 8-28-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.34	0.01	0.095
8	NFA	3.51	0.00	0.083
9	RACIO	3.56	0.01	0.096
10	Autoz	3.56	0.01	0.120
12	Hoff	3.41	0.01	0.145
13	Grand	3.34	0.02	0.054
26	MRA's	3.52	0.03	0.098
27	Husselbring	3.42	—	0.058

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 8-27-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	un mark	3.51	0.02	0.116
<del>2</del>	<del>to fu</del>			
3	Pal 1.9	3.64	0.02	0.148
4	PA. coru	3.66	0.03	0.203
5	Led Res	3.58	0.02	0.100
6	Yeotis	3.54	0.02	0.136
28	FIA	3.49	0.04	0.132
21	Dang	3.46	—	0.064

Comments:

---

---

---

---

---

---

---

---

### DISTRIBUTION TESTING

Date: 8-24-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
11	W Res	3.40	0.03	0.198
16	RA Couv	3.52	0.00	0.053
17	19 Pal	3.58	0.01	0.058
18	RA Fen	3.39	0.00	0.051
19	14 E H	3.57	0.01	0.175
25	Fire 5	3.44	0.02	0.125
30	ADESA	3.68	0.01	0.061

Comments:

---

---

---

---

---

---

---

---



# DISTRIBUTION TESTING

Date: 8-23-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
20	File 3	3.36	0.02	0.154
1	VA MARK	3.43	0.01	0.100
2	10 Fu	3.22	0.02	0.097
3	P11 1.9	3.43	0.03	0.082
4	RA CURV	3.45	0.02	0.113
5	ced Res	3.54	0.01	0.109
24	Gen H.	3.45	0.02	0.090
27	MARA	3.53	0.00	0.081

Comments:

---

---

---

---

---

---

---

---

### DISTRIBUTION TESTING

Date: 8-22-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admir	3.48	.01	0.096
15	Luigi	3.36	.01	0.081
16	RA Court	3.46	.01	0.073
17	Liq Pal	3.51	.01	0.107
18	RA Fen	3.36	.01	0.074
19	14 # H	3.35	.02	0.067
23	Sans	3.50	.01	0.089
29	Maxi	3.51	.01	0.086

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 8-21-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
7	Foss	3.45	0.03	0.163
8	NFA	3.56	0.00	0.091
9	RACID	3.42	0.00	0.071
10	AUTOZ	3.54	0.01	0.070
12	Hoff	3.35	0.01	0.078
13	Grand	3.35	0.01	0.076
22	Hassel	3.41	0.01	0.071
26	MFB	3.56	0.01	0.174

Comments:

---

---

---

---

---

---

---

---

1440  
3.17

### DISTRIBUTION TESTING

Date: 8-20-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	Un Mark	3.47	0.01	0.165
<del>2</del>	<del>Ten Fu</del>			
3	Pal liq	3.56	0.01	0.153
4	RACORV	3.54	0.01	0.164
5	Bed Res	3.55	0.01	0.104
6	Teatis	3.52	0.01	0.136
21	Don	3.44	0.00	0.090
28	FEA	3.49	0.00	0.092

Comments:

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 8-16-18

Technician: KST

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
1	Univ Mkt	3.37	0.02	0.071
3	Lig Pal	5.06 / 5.08	0.16	1.61
4	RA Community	3.58	0.01	0.079
5	CSR	3.50	0.02	0.117
20	Fic 3	3.37	0.01	0.079
30	AD25A	3.52	0.01	0.089

**Comments:**

\* LEAD Replacement in the area

---

---

---

---

---

---

---

---

# DISTRIBUTION TESTING

Date: 8-15-18

Technician: BP

Site ID #	Site Name	Phosphorus mg/L	Iron mg/L	Turbidity NTU
14	Admiral	3.52	0.00	0.060
15	Luigi	3.45	0.00	0.068
16	RA Cove	3.54	0.00	0.064
17	liq Pal	3.56	0.00	0.085
18	RA Fen	3.58	0.04	0.210
19	IVEH	3.49	0.01	0.076
22	Maxi	3.57	0.00	0.076
23	SAMS	3.53	—	0.086
25	File 5	3.75	—	0.318

Comments:

---

---

---

---

---

---

---

---