

Exhibit I

Zewdie, Milcah

From: Kutzing, Sandra <KutzingSL@cdmsmith.com>
Sent: Thursday, February 22, 2018 8:57 AM
To: Smith, David C.; Adebawale, Andrea; Adeem, Kareem; George, John
Subject: RE: NJDEP Mtg Prep: Newark LSL Replacement Program
Attachments: Newark Lead Frequency Distribution_Draft.pdf; Newark_Lead Samples Maps.pdf

Andrea, Kareem, John,

For discussion, attached please find some initial analysis on the lead sampling results based on Newark's LCR compliance sampling. I think we should discuss whether or not it makes sense to share this with DEP at our meeting. We haven't completed the review of the water quality and do not have the results back from EPA yet, but based on what we have so far, it appears that **the sodium silicate has not been effective for Pequannock** and studying alternative treatments (such as orthophosphate at Cedar Grove) will likely be our recommendation. It has clearly worked for the Wanaque system.

It is still early and our recommendations may change once we receive results from the EPA and fully review the system's water quality, but this is where we are currently at.

Sandy

-----Original Appointment-----

From: Smith, David C.
Sent: Wednesday, February 21, 2018 7:17 PM
To: Smith, David C.; Adebawale, Andrea; Adeem, Kareem; George, John; Kutzing, Sandra
Subject: NJDEP Mtg Prep: Newark LSL Replacement Program
When: Thursday, February 22, 2018 12:00 PM-12:30 PM (UTC-05:00) Eastern Time (US & Canada).
Where: Skype Meeting

The intent of this call is to prep ourselves in advance of our 2/23 meeting with NJDEP. We look forward to our discussion.

Dave

.....
[→ Join Skype Meeting](#)

Trouble Joining? [Try Skype Web App](#)

Join by phone

Toll-free number: +1 (844) 566-5330, access code: 22237558 (Dial-in Number) English (United States)
Toll number: +1 (857) 327-8948, access code: 22237558 (Dial-in Number) English (United States)

[Find a local number](#)

Conference ID: 22237558 (same as access code above)

[Forgot your dial-in PIN?](#) | [Help](#)