

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

*Lg Bottle All parameters / All sites*

DATE: 11-14-18 *wed*

TECHNICIAN: ~~AR~~ M

*Sample roll*  
*Sample sites*

↓  
↓

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1) X 14	Admiral (lead)	9:04 am	13.8	0.219	7.66	1.35	1.69
3) X 15	Luigi's	9:25 am	14.1	0.218	7.60	0.71	1.40
4) X 16	RA Court (lead)	9:55 am	12.7	0.217	7.61	1.42	1.76
6) X 17	Liquor Palace (Pb)	10:55 am	12.5	0.216	7.56	1.52	1.85
7) X 18	RA Fenton	<del>11:25 am</del> <del>13.9</del>	<del>12.5</del>	<del>0.218</del>	<del>7.70</del>	1.17	1.47
8) X 19	NEH (lead)	<i>Back</i> 12:30 pm	14.3	0.214	<del>7.70</del> 7.64	1.10	1.45
5) X 29	Maxi Meats	10:30 am	13.5	0.217	7.63	1.35	1.80
X 23	SAMS (Cl <sub>2</sub> only)	8:30 am	13.8	0.219	7.52	1.56	1.80

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING

Parameters All  
eg. Bottle All

DATE: 11-13-18 TUES

TECHNICIAN: [Signature]

*Foss*  
*RA*  
*RA clio*  
*Auto zone*  
*Hoffmans*  
*G*  
*[Signature]*

a) 3)  
2)  
5)  
6)  
7)  
1)  
8)

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
7	(LHPC) Bacteria Foss Church	9:50 am	13.0	0.220	7.73	1.22	1.55
8	(Lead samp) M. Flint Auto	9:24 am	14.5	0.217	7.62	1.58	1.79
9	(Lead samp) RA clio	10:50 am	15.7	0.219	7.64	1.63	1.75
10	(LHPC) Auto zone	11:14 am	13.0	0.219	7.62	1.35	1.79
12	(Lead Sample) Hoffmans	12:15 pm	12.8	0.217	7.67	1.37	1.75
13	(LHPC) Bacteria Grandmas	8:45 am	15.7	0.219	7.61	0.86	1.24
26	(LHPC) Bacteria MR. Os	11:35 am	11.4	0.217	7.61	1.16	1.37
22	Chlorine only Hassel bring (no bacteria)	10:20 am	14.0	0.216	7.74	1.24	1.48

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 11-12-18 Mon

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
	Univ. Market	0840	14.0	.220	7.53	1.37	1.61
HPC 2	Ten Fu	1200 <del>NOT</del>	14.6	.216	7.60	1.59	1.89
HPC 3	Palace liquor	0900	13.7	.218	7.53	1.40	1.64
4	RA Corvum	0925	13.8	.218	7.64	1.42	1.66
5	Cedar Res	1020 <del>1015</del>	14.9	.218	7.70	1.85	2.04
HPC 6	Yeatis	0950	14.7	.216	7.64	1.51	1.72
HPC 28	FIA	1135	14.6	.217	7.57	1.51	1.73
21	Dons	1045	14.6	.216	7.69	1.27	1.51

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 11-9-18 Fri

TECHNICIAN: BP/AR

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC X 11	W. Res	10:55 AM	15.1	0.223	7.63	0.55	1.35
3 X 15	Luigi's	9:20 AM	15.6	0.221	7.64	1.18	1.46
4 X 16	RA Court	9:45 AM	13.8	0.220	7.60	1.15	1.73
5 X 17	Liquor place	10:10 AM	14.0	0.216	7.62	1.46	1.80
X 18	RA Fenton	10:35 AM	15.3	0.222	7.61	1.07	1.42
X 19	NEH	11:34 AM	15.4	0.219	7.53	1.20	1.53
1 X 30	ADESA	8:40 AM	14.4	0.217	7.6	1.56	1.79
<del>22</del>	<del>Hasselbring</del>	<del></del>	<del></del>	<del></del>	<del>7.53</del>	<del></del>	<del></del>
2 X 25	Fire 5	9:00 AM	15.6	0.226	7.74	<del>0.94</del> 1.58	<del>1.20</del> 1.79
	Hamilton		17.1	0.227	7.62	1.15	1.35

**COMMENTS:**

pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 11-8-18 Thur

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
20	Fire #3	0820	15.5	.221	7.53	1.03	1.19
1	UN Market	0845	14.1	.222	7.52	1.13	1.37
2	Ten Fu	1100	15.1	.219	7.56	1.60	1.79
3	Pal 117	0905	14.3	.220	7.51	1.42	1.64
4	Rt Cor	0930	14.1	.221	7.59	1.44	1.65
5	C. Res	0945	14.8	.222	7.72	1.87	2.06
27	Marathon	1125	14.7	.218	7.63	1.65	1.92
29	Maxi	1040	14.8	.219	7.62	1.54	1.79
23	Sams	1140	14.3	.225	7.62	1.51	1.71
24	Gen Sec H.	1005	15.5	.221	7.66	1.33	1.58
	Hamilton						

**COMMENTS:**

pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 11-6-18 Tues

TECHNICIAN: BP/AR

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
X 7	FOSS	0940	15.5	.223	7.62	<del>0.63</del> 0.63	<del>1.07</del> 1.07
HPC X 8	DBP3 NFA	0950	15.5	0.219	7.52	1.60	1.74
HPC X 9	DBP6 RAClio	10:20 Am	16.9	.221	7.55	1.40	1.64
X 10	Autozone	1045	14.2	0.221	7.54	1.45	1.83
HPC X 12	Hoffmans	11:14 Am	14.6	0.220	7.64	0.83	1.07
X 13	Grandmas	0:00 Am	17.4	0.222	7.42	0.86	1.12
HPC X 14	Admiral	0:28 Am	15.5	0.222	7.36	1.33	1.72
HPC X 14	DBP7 NEH	12:00 Am	16.4	0.218	7.57	1.08	1.40
26 X	MR. Bs	11:34 Am	12.9	0.219	7.52	1.11	1.31
X 22	(Clx only no back) Hasselberg	<del>_____</del>					
X	DBP1 McDonalds	09:15	15.5	0.223	7.62	1.24	1.46
X	Hamilton	-	16.8	.229	<del>7.57</del> 7.83	1.05	1.22

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

*BP/AR*

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 11-5-18 Mon

TECHNICIAN: BP/AP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC 1	DBP4 UN. MARKET	09:05	14.9°C	0.223	7.46 <sub>50</sub>	1.10	1.34
HPC 4	RA CORUNNY	09:45 <del>10:05</del>	15.0°C	0.220	7.56	1.27	1.52
HPC 5	Cedar Res	10:25 <del>10:05</del>	15.5°C	0.219	7.59	<del>1.10</del> 1.66	1.97
6	Yentis	10:05/Am	15.6°C	0.219	7.59	<del>1.10</del>	1.65
HPC 16	DBP8 RA COURT	12:05/Am	14.5°C	0.221	7.65	<del>1.36</del> 1.44	1.71
HPC 17	DBP2 Liquor Palace	11:44/Am	14.1	0.218	7.59	<del>1.44</del>	1.71
28	FIA	10:55/Am	18.5°C	0.222	7.62	0.94	1.13
21	(Cl <sub>2</sub> unit) Dons (no bacteria)	11:24/Am	15.1°C	0.221	7.62	1.10	1.98
	DBP 5 Taco bell	09:25/Am					

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 11-2-18 Fri

TECHNICIAN: BP/AR

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	w. Res	11:45 <del>11:10</del>	15.7°C	0.222	7.74	1.14	1.43
16	RA Court	9:35 <del>Am</del>	14.9°C	0.220	7.56	1.40	1.78
17	Liquor Palace	10:00 <del>Am</del>	13.9°C	0.219	7.62	1.40	1.71
18	RA Fenton	11:10 <del>Am</del>	16.5°F	0.221	7.61	1.15	1.34
19	INEM	12:10	16.2°F	0.219	7.59	1.20	1.39
30	ADESA	0850	15.1°C	218.5	7.57	1.50	1.85
25	Cl <sub>2</sub> only Five 5	0910	16.2°C	0.225	7.75	0.89	1.31
	<del>Cooler Run</del>						

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---



**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 11-01-2018 Thurs.

TECHNICIAN: AR/ISP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine	
20	Fire House #3	— Can't Get IN @ 5:50 Am —						
1	Wilder. MARK.	0915	15.5	.222	7.50	1.26	1.51	
2	TEN FU	11:30 Am	16.0	0.221	7.59	1.65	1.94	
3	PALACE LIQUOR	0935	15.2	0.221	7.56	1.35	1.68	
4	RITE AID CO.	10:00 Am	15.1	0.221	7.60	1.33	1.63	
5	Cedar Res.	10:30 Am	15.5	0.222	7.67	1.73	2.03	
27	MARTIN	<del>11:50 Am</del> <del>10:55 Am</del>	15.7	.219	7.58	1.49	1.80	
24	Gen. Health	10:55 Am	15.9	0.222	7.59	1.26	1.52	
	Hamilton		18.9°	0.227	7.73	1.21	1.39	
	Cooler run ?							

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-31-18 Wed

TECHNICIAN: DP/AR

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
14	lead Admiral	9:18 AM	16.4	<del>0.223</del> 0.223	7.62	1.63	1.74
15	Lead Luis	9:40 AM	17.5	0.221	7.61	1.04	1.25
16	lead RA Court	1010	15.7	0.221	7.50	1.50	1.74
17	lead Liquor Palace	1100	15.4	0.218	7.54	1.48	1.73
18	RA Fenton	11:20 AM	16.1	0.222	7.57	1.09	1.29
19	lead NEM	11:55 AM	16.0	0.220	7.57	1.19	1.43
29	maxi	1025	15.8	0.221	7.56	1.60	1.74
23	Chlorine ONLY Sams	9:45 AM	15.9°C	0.225	7.46 <sub>50</sub>	1.52 mg/L	1.69 mg/L

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-30-18 Tues

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
7	Foss	0925	14.9	.223	7.54	1.26	1.53
8	WFA	0900	16.5	.219	7.42	1.66	1.84
9	RA Clio	1015	17.4	.221	7.55	1.15	1.33
10	Auto zone	1040	14.9	.222	7.53	1.62	1.79
12	Hoffmans	1105	15.7	.221	7.58	1.41	1.60
13	Grandmas	0835	18.5	.223	<del>7.48</del> 7.53	0.97	1.09
26	MR Bs	1120	14.4	.219	7.56	1.15	1.23
22	Hasselbring	0950	16.5	.221	7.66	1.25	1.40
	Hamilton	1151	17.8	.229	7.89	1.18	1.29

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-29-18 MON

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1	UNIV. MARKET	0840	15.7	.222	7.42	1.45	1.61
2	TEN FV	1110	15.8	.220	7.65	1.72	1.93
3	PALACE LIQUOR	0905	15.7	.221	7.43	1.45	1.59
4	RA CORUNNA	0930	15.4	.223	7.55	1.42	1.58
5	CEDAR RES	1015	16.2	.221	7.67	1.96	2.09
6	YEOPIS	0955	16.6	.222	7.51	1.49	1.63
28	FEA	1130	17.5	.220	7.56	1.60	1.79
21	DONS	1050	16.4	.221	7.61	1.31	1.46

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-26-18 Fri

TECHNICIAN: BP

Phos  
Phos

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	W. Res	1050	16.3	.222	7.66	1.24	1.40
16	RA Court	0925	16.3	.220	7.46	1.48	1.63
17	Liquor Palace	1015	17.9	.221	7.49	1.62	1.78
18	RA Fenton	1035	17.4	.222	7.45	1.19	1.34
19	NEH	1125	16.8	.219	7.51	1.26	1.40
30	ADESA	0835	16.5	.220	7.46	1.65	1.82
25	Fire #5	0900	17.0	.223	<del>7.54</del> 7.61	1.23	1.32
Phos	UN MARK	3.18					
Phos	WIGIS	3.31					

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-25-18 Thur.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
20	Fire #3	0845	17.4	.221	7.40	1.12	1.34
1	Univ. Market	0910	16.5	.223	7.44	1.16	1.30
2	Ten Fu	1120 <del>1430</del>	19.0	.221	7.52	1.22	1.38
3	Palace Liquor	0935	16.3	.221	7.44	1.44	1.61
4	RA Corvum	1000	16.3	.224	7.57	1.42	1.60
5	Cedar Res	1015	16.5	.222	7.64	2.02	2.18
27	Marathon	1145	17.6	.220	7.50	1.74	1.91
24	Genesee Health	1045	16.5	.222	7.56	1.29	1.46
Phos 3.81	Luigs						
3.16	Hamilton		18.9	.226	7.71	1.24	1.44

**COMMENTS:**

pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-24-18 Wed

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
14	Admida	0905	17.3	.222	7.58	1.62	1.85
HPC 15	Luisis	0930	19.2	.220	7.49	0.99	1.15
16	RA Court	0950	16.2	.219	7.49	1.56	1.75
17	Liquor Palace	1030	17.1	.219	7.53	1.52	1.72
HPC 18	RA Fenton	1055	16.0	.222	7.58	1.21	1.43
HPC 19	NEH	1125	18.4	.221	7.54	1.02	1.16
HPC 24	Maxi	1015	16.7	.220	7.62	1.63	1.79
23	Sams	0835	14.8	.223	7.53	1.44	1.61
	HASSCI ✓						
	GMAS ✓						
	FOSS ✓						

**COMMENTS:**

pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-23-18 Tues

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC 7	Foss	0925	15.8	.222	7.49	1.37	1.49
8	NFA	0900	16.9	.220	7.38	1.59	1.76
9	RA clio	1010	17.0	.221	7.52	1.48	1.66
HPC 10	Autozone	1035	16.0	.222	7.51	1.51	1.76
12	Hoffmans	1055	17.0	.220	7.63	0.93	1.18
HPC 13	Grandmas	0835	19.0	.222	7.44	0.89	1.01
HPC 26	MR Bs	1110	15.0	.221	7.57	1.16	1.32
22	Hasselbring	0950	17.7	.222	7.64	0.96	1.15
	Hamilton	1155	18.7	.229	7.81	1.04	1.21
Phos 3.14	10 FU ✓						
Phos 3.29	Pal via ✓						
Phos 3.14	Dons						

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!



**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-22-18 Mon

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1	Univ. Market	0845	17.0	.223	7.50	1.21	1.40
HPC 2	Ten Fu	1120	23.3	.223	7.54	1.27	1.42
HPC 3	Palace Liquor	0915	17.0	.221	7.51	1.30	1.51
4	RA Corunna	0940	15.1	.224	7.60	1.30	1.52
5	Cedar Res	1040	17.0	.222	7.69	2.00	2.27
HPC 6	Yeotis	1000	17.8	.221	7.56	1.38	1.54
HPC 28	FIA	1135	22.1	.221	7.58	1.55	1.78
21	Dons	<del>1050</del> 1050	18.3	.222	7.61	1.19	1.43

COMMENTS:  
pH Range 7.2-7.9

Phosphate > 3.1 at all times!

## CITY OF FLINT WATER PLANT DISTRIBUTION SAMPLING

DATE: 10-19-18 Fri

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC 11	W. Res	1020	17.1	.224	7.31	1.29	1.45
16	RA court	0920	17.6	.222	7.31	1.55	1.73
17	Liquor Palace	0955	17.1	.220	7.29	1.55	1.61
18	RA Fenton	1010	17.4	.223	7.22	1.23	1.37
19	NEH	1110	17.9	.222	7.43	1.37	1.58
HPC 30	ADESA	0845	17.5	.222	7.30	1.62	1.85
25	Fire #5	0900 0910	21.6	.230	7.52	1.03	1.18

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

## CITY OF FLINT WATER PLANT DISTRIBUTION SAMPLING

DATE: 10-18-18 Thu.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC 20	Fire #3	0840	18.6	.224	7.27	1.24	1.37
1	UNIV. MARKET	0905	17.6	.228	<del>6.61</del> 7.21	1.17	1.46
2	Gen FU	1101	26.4	.227	<del>6.61</del> <sup>7.36</sup> <del>7.21</del>	1.26	1.45
3	Palace Liquor	0930	16.6	.223	<del>6.61</del> 7.24	1.36	1.55
4	RA Corvann	0955	17.5	.221	<del>7.36</del> 7.39	1.43	1.53
5	Cedar Res	1015	17.4	.225	7.51	1.78	2.10
HPC 27	Marathon	1155	17.3 <del>17</del>	.222 <del>.225</del>	7.36	1.70	1.88
24	Gen Health	1041	17.9	.225	7.49	1.27	1.40
Phos 3.17	Hamilton	1210	20.0	.232	7.66	1.12	1.28

**COMMENTS:**

pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-17-18 wed

TECHNICIAN: BP

	Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC	14	Admiral	0850	18.4	.224	7.27	1.59	1.75
	15	Luigi's	0915	19.5	.223	7.25	1.06	1.23
HPC	16	RA Court	0935	17.5	.224	7.21	1.52	1.68
HPC	17	Liquor Palace	1020	16.2	.223	7.30	1.58	1.66
	18	RA Fenton	1050	17.8	.223	7.42	1.12	1.28
HPC	19	NEH	1120	18.7	.222	7.37	1.22	1.36
	29	Maxi	1000	17.8	.224	7.29	1.62	1.84
	23	SAMS	0825	18.0	.227	7.34	1.49	1.66

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-16-18 Tues

TECHNICIAN: B.P.

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
7	Foss	0925 <del>0900</del>	16.4 <del>17.8</del>	.226 <del>.222</del>	7.37 <del>7.29</del>	1.33 <del>1.64</del>	1.49 <del>1.79</del>
8	NFA	0900	17.8	.222	7.29	1.64	1.79
9	RA Cliv	1010	19.6	.224	7.38	1.09	1.17
10	Auto Zone	1025	17.9	.223	7.39	1.59	1.69
12	Hoffmans	1050	18.9	.224	7.42	0.87	0.97
13	Grandmas	1155	19.7	.224	7.49	0.79	0.93
26	MR Ds	1110	16.0	.222	7.40	1.08	1.24
22	Hassel bring	0950 <del>0945</del>	17.7	.223	7.47	1.27	1.41
Phos 3.28	Hamilton	1135	20.7	.232	7.83	0.96	1.10

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-15-18 Mon

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HP 1	Univ. Market	0835	18.4	.226	7.51	1.39	1.43
2	Ten Fu	1115	28.6	.228	7.46	1.25	1.41
3	Palace Liquor	0900	17.8	.225	7.50	1.43	1.55
HP 4	RA Corona	0920	18.5	.225	7.55	1.29	1.47
HP 5	Cedar Res	1010	17.9	.227	7.72	1.78	1.86
6	Ycotis	0945	18.9	.224	7.60	1.08	1.23
28	FIA	1135	20.0	.224	7.50	0.94	1.04
21	Dons	<del>1045</del> 1050	19.8	.221	7.74	1.00	1.15

**COMMENTS:**

pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-12-18 Fri

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	W. Res	1050	17.6	.224	7.82	1.31	1.47
16	RA Court	0930	18.3	.223	7.63	1.47	1.61
17	Liquor Palace	0955	17.4	.222	7.70	1.55	1.69
18	RA Fenton	1025	18.8	.225	7.69	1.03	1.16
19	MBH	1120	19.2	.222	7.67	1.23	1.36
30	ADUSA	0840	18.2	.222	7.70	1.56	1.80
25	Fire #5	0910	18.6	.230	7.76	1.08	<del>1.18</del>
Phos 324	Hamilton		20.7	.231	7.81	1.12	1.28

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-11-18 Thur.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
20	File #3	0840	19.3	.223	7.47	1.24	1.32
1	UNiv. marked	0905	19.4	.225	7.50	1.17	1.25
2	Gen Fu	1120	29.1	.229	7.48	1.16	1.28
3	Pal lig	0930	18.7	.223	7.54	1.40	1.51
4	RA column	0950	19.0	.224	7.49	1.35	1.51
5	Cedar Res	1010	18.0	.226	7.67	1.89	1.98
27	Marathon	1150	18.8	.222	7.48	1.69	1.80
24	Genesee Health	1050	18.2	.222	7.73	1.29	1.43
	cooler	Run					

COMMENTS:

pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!



**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-10-18 wed

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
14	Admiral	0850	19.2	.222	7.58	1.56	1.77
KPC 15	Luigi's	0935	21.0	.221	7.64	0.84	0.98
16	RA Court	0915	18.9	.221	7.63	1.52	1.66
17	Liquor Palace	1020	18.1	.220	7.61	1.52	1.74
KPC 18	RA Fenton	1040	19.7	.222	7.65	1.06	1.30
KPC 19	HEH	1120	20.4	.219	7.59	1.17	1.28
KPC 29	Maxi	1000	18.6	.223	7.54	1.52	1.77
23	Sams	0825	20.0	.224	7.57	1.35	1.56
Phos 3.21	Hamilton		21.9		7.68	1.07	1.14

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-9-18 Tues

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPc 7	Foss	0925	19.8	.222	7.62	1.23	1.32
8	W.F.A.	0900	18.9	.217	7.57	1.41	1.67
9	RAClio	1015	20.3	.222	7.56	1.58	1.82
HPc 10	Autozone	1035	18.4	.223	7.69	1.51	1.66
11	Hoffmans	1100	20.0	.221	7.61	0.80	1.00
HPc 13	Grandmas	0835	21.0	.221	7.46	0.84	1.01
HPc 26	M.R. Bs	1120	17.2	.219	7.66	0.94	1.20
22	Hasselbring	0950	18.9	.220	7.73	1.22	1.44
HPc	3602 Brownell	1253	19.2	.221	7.84	1.15	1.27
w/ w/out	with						
	w/out	1258	19.6	.220	7.83	1.08	1.32

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-08-18 Mon

TECHNICIAN: BP

HPC  
HPC  
HPC  
HPC  
HPC

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1	UAs Market	0925	19.4	.223	7.44	1.29	1.42
2	Ten Fu	1130	27.4	.217	7.45	1.14	1.35
3	Palace liquor	0950	18.4	.220	7.53	1.35	1.54
4	RA Corunna	1010	19.3	.220	7.59	1.33	1.52
5	Cedar Res	1050	18.3	.222 .220	7.67	1.82	2.09
6	Yeatis	1035	19.1	.219	7.59	1.34	1.53
28	FEA	1150	20.1	.218	7.50	1.45	1.63
21	Dons	1110	19.8	.221	7.69	1.20	1.41
Phos. 3.22	Hamilton		x 20.3		x 8.07	x 0.80	x 0.97
810 391 <del>2260</del>	<del>3602 Brownell Blvd</del>						

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-5-18 Fri

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	W. Res	1035	18.0	.223	7.74	1.24	1.41
16	RA Court	0935	19.0	.221	7.44	1.32	1.69
17	Liquor Palace	0955	17.9	.220	7.46	1.57	1.75
18	RA Fenton	1020	19.4	.224	7.58	0.95	1.18
19	NEH	1110	18.8	.222	7.63	1.29	1.48
30	ADUSA	0850	18.0	.221	7.44	1.70	1.90
25	Fire #5	<del>0900</del> 0910	19.1	.223	7.48	1.40	1.57
	Hamilton	1140	20.5	.229	7.84	1.10	1.29

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 4<sup>th</sup> 10-4-18 Thur.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1-PC 20	Fife #3	0840	20.0	.223	7.53	0.99	1.18
1	UN Market	0905	19.8	.222	7.57	1.16	1.41
2	Ten Fu	<del>0925</del> 1115	29.3	.230	7.51	1.17	1.38
3	Palucc liquor	0925	19.6	.224	7.56	1.04	1.14
4	RA Corunn	0950	20.1	.224	7.61	1.21	1.46
5	Cedar Res	1010	18.5	.223	7.76	1.88	2.13
1-PC 27	Marathon	1135	19.1	.220	7.63	1.63	1.86
24	Gen Health	1050	19.0	.221	7.60	1.14	1.32

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-3-18 wed

TECHNICIAN: Bp

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC 14	Admiral	0850	19.9	.222	7.57	1.55	1.74
15	Luigi's	0925	21.1	.222	7.54	0.93	1.12
HPC 16	DBP RA Court	0950	19.4	.221	7.55	1.45	1.63
HPC 17	DBP Liquor Palace	1035	18.5	.220	7.60	1.45	1.70
18	RA Fenton	1055	19.8	.222	7.60	1.12	1.35
HPC 19	DBP NEH	1130	20.2	.220	7.62	1.11	1.31
21	Maxi	1015	19.3	.221	7.55	1.53	1.77
23	Sams	0825	19.2	.225	7.44	1.39	1.48
	DBP McDonalds	0900					

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-02-18 Tues

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
7	Foss	0925	18.7	.223	7.54	1.18	1.33
HPC 8	DBP3 NFA	0900	19.3	.220	7.39	1.62	1.86
HPC 9	DBP6 RA Cl.0	1020	20.8	.222	7.58	1.47	1.76
10	Autozone	1035	19.0	.222	7.41	1.55	1.74
HPC 12	Hoffmans	1100	20.8	.221	7.61	0.60	0.76
13	brandmas	0835	21.8	.223	7.44	0.83	1.03
26	MR. Dr	1120	17.5	.220	7.52	0.69	0.98
22	Hassel bring	0950	19.3	.221	7.68	1.20	1.32

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 10-01-18 Mon

TECHNICIAN: BP

OBP  
HPC

HPC

HPC

OBP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
OBP 1	OBP4 Un. Market	0840	20.0	.223	7.48	1.11	1.31
2	Ten Fu	Not	Open				
3	Palace liquor	0900	19.1	.223	7.44	1.25	1.39
4	RA Corona	0935	19.7	.222	7.62	1.25	1.42
5	Cedar Res	1020	18.7	.224	7.77	1.88	2.10
6	Yeotis	1005	18.9	.222	7.57	1.32	1.57
28	FIA	1120	20.6	.223	7.64	0.86	1.01
21	Dons	1050	20.0	.220	7.70	1.04	1.27
OBP5	3606 Corona Taco bell	0920					

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!



**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-28-18 Friday

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	W. Res	1025	19.0	.221	7.65	1.28	1.52
16	RA COURT	0925	20.2	.223	7.47	1.38	1.61
17	Liquor Palace	0950	19.6	.220	7.49	1.50	1.72
18	RA FENTON	1015	21.1	.223	7.50	1.04	1.22
19	NEH	1110	20.3	.220	7.45	1.11	1.31
30	ADESA	0830	20.2	.223	7.40	1.56	1.80
25	<del>File #3</del>						

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-27-18 Thur.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
20	Fire #3	0843	20.8	.224	7.45	0.73	0.93
1	Un. Market	0905	21.0	.226	7.47	1.11	1.27
2	Ten FU	1115	29.7	.230	7.47	0.98	1.37
3	Palace liquor	0935	19.8	.222	7.46	1.32	1.48
4	RA Corona	0955	20.2	.223	7.57	1.26	1.49
5	Cedar Res	1010	19.0	.224	7.71	1.87	2.08
27	Marathon	1140	20.0	.220	7.41	1.65	1.90
24	Gen. Health	1055	19.5	.221	7.57	1.29	1.50

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-26-18 Wed

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
14	Admiral	0950	20.7	.224	7.62	1.56	1.77
<del>15</del>	<del>Luigi's</del>	<del>0920</del>	<del>22.1</del>	<del>.222</del>	<del>7.51</del>	<del>0.94</del>	<del>1.12</del>
16	RA Court	0940	21.0	.221	7.53	1.38	1.61
17	Liquid Palace	1020	19.1	.221	7.54	1.47	1.77
18	RA Fenton	1045	21.2	.224	7.62	1.03	1.22
19	IVEH	1130	21.3	.221	7.58	1.10	1.32
29	Maxi	1000	20.5	.222	7.57	1.62	1.83
23	SAMS	0830	21.7	.225	7.57	1.42	1.58

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-25-18 TUES

TECHNICIAN: BP

	Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC	7	Foss	0920	20.8	.224	7.50	1.21	1.39
	8	NFA	0840	20.4	.221	7.48	1.23	1.77
	9	RACIO	0950	21.4	.224	7.51	0.78	0.99
HPC	10	Auto Zone	1010	20.1	.223	7.46	1.41	1.64
	12	Hoffmas	1035	22.3	.225	7.53	0.92	1.10
HPC	13	Grandmas	1120	22.5	.226	7.58	0.65	0.80
HPC	26	M.R.D.s	1100	18.1	.221	7.50	0.94	1.13
	22	Hasselbring	0900	20.0	.222	7.57	1.00	1.15

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 09/24/19 Mon

TECHNICIAN: BP

HPC  
HPC  
HPC  
HPC  
HPC

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1	univ. market	0840	21.3	.225	7.48	1.04	1.23
2	Ten Fu	1110	29.3	.231	7.53	1.16	1.27
3	Palace liquor	0905	20.1	.223	7.50	1.28	1.47
4	RA coronna	0930	20.6	.224	7.57	1.29	1.44
5	Ced Res	1010	19.0	.224	7.70	1.95	2.10
6	Yeotis	0955	20.6	.222	7.52	1.40	1.62
28	FEA	1130	21.4	.226	7.47	0.79	0.97
21	Dons	1040	21.1	.222	7.65	1.07	1.21

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-21-18 Fri

TECHNICIAN: BP

	Site ID#	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC	3	Palace liquor	1040	20.5	.221	7.48	1.33	1.47
	5	Ced Res	1020	19.6	.225	7.61	1.83	2.07
HPC	11	w. Res	1100	20.0	.222	7.66	1.26	1.49
	16	RA CORR	0915	21.1	.220	7.51	1.47	1.67
	17	liquor Palace	0940	20.3	.223	7.54	1.54	1.76
	18	RA Fenton	1005	21.7	.224	7.43	1.07	1.26
HPC	19	NEH	1130	22.3	.221	7.57	1.16	1.34
	30	ADESA	0830	21.1	.223	7.55	1.45	1.61
	25	Filt #5	0850	22.0	.224	7.64	0.88	1.08

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

3871 N Oak

DATE: 09-19-18 wed

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC 14	Admiral	0855	21.2	.220	7.54	1.54	1.68
15	Luigi's	<sup>0915</sup> <del>0910</del>	21.7	.220	7.42	1.01	1.22
HPC 16	RA Court	0935	21.5	.222	7.51	1.39	1.59
HPC 17	Liquid Palace	1020	20.0	.219	7.44	1.44	1.57
18	RA Fenton	1045	21.5	.225	7.49	0.99	1.14
HPC 19	NEH	1110	22.2	.213	7.56	1.13	1.27
29	Maxi	1000	20.5	.221	7.41	1.34	1.70
23	Sams	0825	22.3	.224	7.51	1.36	1.50

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

March 13  
Van Ande  
net

DATE: 4-18-18 Tues

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
7	Foss	0925	21.9	.225	7.50	1.20	1.40
HPC 8	N. Flint Auto	0905	21.0	.220	7.58	1.54	1.78
HPC 9	RA Cliv	1015	21.7	.222	7.53	1.60	1.88
10	Autozone	1035	20.7	.222	7.61	1.51	1.70
HPC 12	Hoffmans	1100	22.8	.224	7.56	0.96	1.11
13	Grandmas	0835	22.6	.224	7.55	0.90	1.06
26	MR Bs	1120	18.8	.221	7.53	0.97	1.25
27	Hasselbring	0945	20.0	.221	7.70	1.08	1.26

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---



**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-17-18 MON

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC 1	UNIV. MARKET	0840	22.2	.225	7.55	0.98	1.13
2	TEN FU	1105	28.1	.230	7.54	1.12	1.36
3	Palace liquor	0910	20.6	.221	7.55	1.11	1.38
HPC 4	RA CORUNNA	0930	21.6	.222	7.60	1.24	1.41
HPC 5	Cedar Res	1015	20.3	.222	7.75	1.46	1.85
6	Ycotis	1005	20.4	.221	7.50	1.58	1.74
28	FIA	1125	22.0	.223	7.52	1.54	1.65
21	DONS	1040	21.1	.222	7.64	1.16	1.27

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-14-18 Fr.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	w Res	1025	19.3	.223	7.83	1.35	1.56
16	RA Court	0920	21.0	.222	7.62	1.42	1.56
17	Liquor Palace	0945	19.7	.220	7.45	1.53	1.71
18	RA Fenton	1005	21.6	.224	7.58	1.07	1.22
19	NEH	1100	22.4	.221	7.48	1.11	1.32
30	ADESA	0840	21.2	.219	7.41	1.63	1.78
25	Fire #5	0855	22.4	.228	7.61	0.91	1.03

COMMENTS:  
pH Range 7.2 – 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-13-18 Thur.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
20	Fire #3	0840	21.5	.224	7.63	0.89	1.16
1	Univ. Market	0905	21.7	.225	7.55	1.19	1.34
2	Ten Fu	1120	27.7	.227	7.50	1.12	1.27
3	Palace Liquor	0930	20.4	.221	7.60	1.33	1.43
4	RA Corunna	0955	21.2	.222	7.67	1.34	1.48
5	Cedar Res	1010	19.3	.224	7.81	1.92	2.12
27	Marathon	1140	20.1	.220	7.52	1.62	1.81
24	Gen. Health	1055	19.6	.224	7.65	1.12	1.25

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-12-18 wed

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
14	Admiral	0900	21.1	.224	7.63	1.48	1.72
HPC 15	Luigis	0920	22.1	.224	7.60	1.17	1.31
16	RA Court	0945	21.1	.223	7.66	1.47	1.74
HPC 17	Litvor Palace	1040	19.0	.220	7.66	1.40	1.68
HPC 18	RA Fenton	1105	21.4	.228	7.63	0.97	1.14
HPC 19	NEH	1145	22.0	.222	7.65	1.05	1.26
HPC 22	Maxi	1015	20.3	.222	7.59	1.51	1.73
23	Sams	0840	21.8	.227	7.30	1.41	1.63

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-11-18 Tues

TECHNICIAN: BP

	Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC	7	Foss	0935	20.5	.224	7.38	1.35	1.56
	8	N.F. Auto	0905	20.4	.221	7.32	1.67	1.84
	9	RA Clid	1025	21.6	.225	7.36	1.56	1.75
HPC	10	Autozone	1045	21.2	.224	7.44	1.51	1.70
	12	Hoffmans	1110	22.9	.226	7.54	0.71	0.87
HPC	13	Grand Mas	0835	23.5	.226	7.32	0.81	1.03
HPC	26	MR. Bs	1140	18.6	.223	7.54	0.41	0.57
	22	Hasselbring	1000	20.3	.223	7.59	1.23	1.40

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-10-18 Mon

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
	UNIV. MARKET	0840	21.9	.225	7.42	1.36	1.55
HPC 2	Ten Fu	1120	29.0	.232	7.43	1.11	1.29
HPC 3	Palace liquor	0905	20.6	.224	7.50	1.30	1.50
4	RA corona	0930	21.2	.227	7.57	1.32	1.51
5	cedar Res	1010	19.2	.226	7.66	1.95	2.18
HPC 6	Yeatis	0955	20.9	.223	7.58	1.42	1.63
HPC <del>28</del>	FIA	1140	22.3	.226	7.63	1.01	1.16
<del>28</del>	Dons	1100 <del>105</del>	21.3	.223	7.59	1.20	1.34

COMMENTS:  
pH Range 7.2-7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-7-18 Fr.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	W. Res	1030	20.2	.227	7.62	1.37	1.57
16	RA Court	0910	21.4	.227	7.45	1.26	1.53
17	Liquor Palace	0950	20.3	.226	7.47	1.51	1.68
18	RA Fenton	1010	22.3	.228	7.54	0.99	1.16
19	NEH	1110	22.8	.225	7.67	0.90	1.19
30	ADESA	0825	21.9	.225	7.52	1.60	1.77
25	Fire 5	0850	21.9	.232	7.58	0.89	1.01

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-6-18 Thu.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
20	Fire #3	0835	21.5	.229	7.25	0.78	0.97
1	VA Mark	0850	23.2	.252	7.27	1.01	1.13
2	Ten Fu	0150	29.8	.236	7.41	1.12	1.27
3	Pat liq	0915	21.3	.231	7.28	0.97	1.11
5	Ced Res	0930	19.9	.234	7.34	1.81	1.99
27	Marathon	1120	20.8	.224	7.62	1.60	1.73
28	FIA	1025	21.6	.230	7.32	0.87	1.05
24	Gen. Health						
	Hamilton	1100	22.0	.235	7.89	1.04	1.18

**COMMENTS:**

pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!



**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-5-18 Wed

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
4	RA CORUM	0850	21.9	.226	7.25	1.35	1.53
14	Admiral	0945	21.6	.225	7.48	1.50	1.72
15	Luigi's	1005	22.4	.225	7.47	1.06	1.22
16	RA COURT	1025	21.4	.228	7.52	1.41	1.60
17	LIQUOR PLACE	1110	20.6	.229	7.65	1.55	1.70
18	RA FENTON	1120	22.1	.230	7.62	0.80	1.00
19	HEU	1155	22.7	.227	7.75	0.91	0.98
29	Maxi	1045	20.7	.229	7.65	1.49	1.74
23	SAMS	0920	22.8	.227	7.43	1.43	1.61

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 9-4-18 Tues

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1	Univ. Market	1115	22.3	.225	7.71	1.17	1.37
5	Cedar Res	1135	20.2	.228	7.63	1.76	1.93
7	Foss	0940	21.2	.225	7.49	1.42	1.60
8	N. Flint Auto	0900	21.9	.224	7.41	1.51	1.70
9	RA Cl.0	1005	22.0	.228	7.46	1.56	1.78
10	Auto zone	1030	21.2	.226	7.57	1.50	1.69
12	Hoffmans	1055	23.5	.228	7.52	1.28	1.51
13	Grand mas	0825	23.5	.227	7.31	0.84	0.97
26	MR. Bs	1240	19.4	.223	7.51	1.25	1.36
21	Dons	1210	23.0	.225	7.51	1.21	1.30
22	Hassel bring	0920 <del>0415</del>	20.6 <del>.223</del>	.223	7.46	1.08	1.25

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-31-18 Fr.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	W. Res	1025	20.2	.227	7.31	1.38	1.57
16	RA Court	0910	22.0	.229	7.36	1.32	1.51
17	Liquid Place	0940	20.6	.230	7.37	1.54	1.81
18	RA Fenton	1005	22.4	.231	7.35	1.08	1.23
19	NEH	1110	22.6	.226	7.54	0.97	1.19
30	ADESA	0825	21.5	.228	7.30	1.36	1.55
25	Fire #5	0850	23.1	.236	7.44	0.80	0.95

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-30-18 Thur.

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
20	Fire #3	0845	21.6	.228	7.24	1.05	1.21
1	Univ. Market	0910	22.4	.230	7.37	1.16	1.36
2	Ten Fu	1120	22.0	.229	7.62	1.06	1.31
3	Pal 1.9	0935	21.0	.230	7.40	1.32	1.50
4	RA Corunna	1000	21.6	.230	7.57	1.30	1.55
5	Cedar Res	1025	19.6	.229	7.44	1.63	1.88
27	Marathon	1140	20.5	.228	7.57	1.69	1.87
24	Genesee Head	1100	19.7	.232	7.55	1.12	1.25

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-29-18 Wed

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
14	Admiral	0845	21.5	.229	7.27	1.60	1.79
HPC 15	Luigi's	0910	23.0	.228	7.43	1.10	1.27
16	RA Court	0935	21.5	.227	7.45	1.49	1.66
17	liquor palace	1035	20.7	.227	7.56	1.52	1.74
HPC 19	RA Fenton	1100	22.3	.231	7.51	1.03	1.19
19	NEH	1130	22.4	.229	7.70	0.96	1.03
HPC 29	Maki	1000	20.6	.229	7.51	1.57	1.82
23	SAMS	0823	22.7	.231	7.23	1.35	1.53

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-28-18 Tues

TECHNICIAN: BP

	Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC	7	Foss	0920	21.0	.229	7.38	1.31	1.58
	8	NF Auto	0845	21.1	.226	7.40	1.70	1.89
	9	RA Clio	1010	21.8	.229	7.45	1.65	1.81
HPC	10	Autozone	1035	20.7	.228	7.61	1.58	1.77
	12	Hoffmans	1055	22.8	.230	7.59	0.92	1.13
HPC	13	Grandmas	0825	23.4	.230	7.22	0.90	1.06
HPC	26	MR. Bs	1120	19.0	.225	7.60	1.31	1.49
	27	Hasselbring	0945	20.4	.228	7.49	1.10	1.32

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-27-18 Mon

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1	Univ. Market	0825	22.2	.227	7.29	1.16	1.36
HPC 2	Ten Fu						
HPC 3	Palace Liquor	0850	20.7	.226	7.51	1.37	1.58
4	RA coronna	0920	21.4	.227	7.61	1.35	1.57
5	Cedar Res	0955	19.2	.227	7.62	1.77	1.91
HPC 6	Yedtis	0940	22.1	.228	7.50	1.28	1.47
HPC 28	FEA	1105	21.0	.229	7.73	0.96	1.18
21	Don S	1035	22.0	.230	7.62	1.04	1.25

COMMENTS:  
pH Range 7.2-7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-24-18 Frid

TECHNICIAN: BP

HPC

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
11	W. Res	1025	19.5	.228	7.60	1.18	1.36
16	RA Court	0925	21.4	.229	7.63	1.50	1.69
17	Liquor Palace	0950	20.5	.223	7.59	1.52	1.67
18	RA Fen	1010	22.4	.229	7.60	1.15	1.34
19	NEH	1110	22.2	.223	7.70	0.97	1.13
25	Fire #5	0900	21.7	.230	7.56	0.99	1.16
30	ADESA	0835	21.0	.228	7.26	1.64	1.98

HPC

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---



**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-23-18 Thur

TECHNICIAN: BP

HPLC

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
20	Fire #3	0835	21.7	.228	7.21	0.96	1.14
1	UN Market	0900	23.1	.229	7.45	0.92	1.12
2	Ten EV	1100	29.8	.232	7.51	1.20	1.42
3	P11 liquor	0920	20.8	.224	7.52	1.18	1.40
4	RA coronna	0940	21.4	.227	7.57	1.25	1.40
5	Ced Res	1005	19.2	.228	7.66	1.85	2.06
24	Genesee Health	1040	20.2	.227	7.59	1.24	1.41
27	Marathon	1125	20.4	.223	7.69	1.69	1.93

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-22-18 Wed

TECHNICIAN: BP

HPC

HPC

HPC

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
14	Admiral	0845	21.2	.226	7.46	1.45	1.71
15	Luigi's	0905	23.1	.225	7.42	1.00	1.22
16	RA Court	0930	21.6	.226	7.46	1.34	1.60
17	Liquor Palace	1005 <del>0950</del>	20.2 <del>22</del>	.228	7.62	1.58	1.78
18	RA Fenton	1030	22.2	.228	7.59	1.05	1.22
19	IXEH	1115	22.4	.224	7.67	1.00	1.17
21	Mexi	0950	20.4 <del>22</del>	.227	7.51	1.48	1.73
23	Sams	0825	22.5	.227	7.28	1.36	1.59

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 08-21-18 Tues

TECHNICIAN: BP

	Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HP	7	Foss	0915	21.2	.225	7.45	1.29	1.48
	8	ANFA	0855	21.7	.223	7.40	1.64	1.83
	9	RA Cio	1015	21.7	.227	7.37	0.85	1.00
HP	10	Auto zone	1037	21.0	.227	7.56	1.56	1.72
	12	Hoffmans	1100	24.1	.228	7.47	0.61	0.80
HP	13	Grandmas	0825	23.6	.227	7.21	0.77	0.95
HP	<del>26</del>	MR Bs	1200	19.0	.224	7.48	1.27	1.47
	<del>22</del>	Hassol bring MR B	0945	20.1	.224	7.45	1.05	1.21

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 08-20-18 Mon

TECHNICIAN: BP

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1	UN Market	0944	23.2	.231	7.23	1.20	1.39
HPC 2	Ten Fu	Closed					
HPC 3	Pal. liquor	1000	21.1	.226	7.40	1.37	1.54
4	R.A. Corunna	1020	21.9	.225	7.44	1.38	1.55
5	Ced Res	1100	19.6	.229	7.72	1.77	2.04
HPC 6	Yeatis	1045	21.4	.228	7.55	1.40	1.64
21	Dons	1120	22.5	.227	7.60	1.14	1.32
28	FIA	1145	22.1	.225	7.63	1.49	1.73

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

Ten Fu closed Thursday and Monday

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-16-18 Thursday

TECHNICIAN: KST

Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
1 30	ADESA	0829	22.2	.227	7.70	1.63	1.84
2 20	Fine #3	0858	21.8	.226	7.73	1.12	1.25
3 1	Univ Mkt	0918	23.3	.229	7.64	1.12	1.29
4 2	Ten Fo	NOT OPEN					
5 3	Palace Hig	0940	20.2	.227	7.70	1.33	1.60
6 4	RA Coruna	1000	30.6	.231	7.66	1.04	1.31
7 5	Cedar St Res	1012	19.0	.229	7.85	1.74	1.98

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!

---



---



---

**CITY OF FLINT WATER PLANT  
DISTRIBUTION SAMPLING**

DATE: 8-15-18 wed

TECHNICIAN: BP

	Site ID #	Site Name	Time	Temp.	Spec. Cond.	pH	Free Chlorine	Total Chlorine
HPC	14	Admiral	0910	20.6	.226	7.56	1.47	1.69
	15	Loigis	0930	22.5	.227	7.58	1.18	1.37
HPC	16	RA Court	0950	22.0	.224	7.62	1.44	1.63
HPC	17	Liquor Palace	1030	19.9	.223	7.60	1.55	1.79
	18	RA Fenton	1100	22.1	.230	7.60	0.84	0.99
HPC	19	NEH	1130	23.5	.225	7.63	1.07	1.24
	29	Maxi	1010	20.4	.224	7.64	1.54	1.72
	23	Sams	0850	22.5	.228	7.41	1.31	1.40
	25	Fire #5	0830	21.5	.231	7.30	0.89	1.06

COMMENTS:  
pH Range 7.2 - 7.9

Phosphate > 3.1 at all times!